



- Type, batch or serial number or any other element allowing identification of the product

H1Z2Z2-K

Range: cross section from 4,00 to 120 mm²

Lot number: as indicated on cable, label and delivery note

- Declared performance

Unique identification code	Reaction to fire class	Dangerous substances
H1Z2Z2-K	Dca-s2,d2,a1	None
Harmonized technical specification EN 50575:2016		

- System of assessment and verification of constancy of performance of the product

System AVCP 3

- Notified product certification body

L.S. Fire Testing Institute Srl (n°2479)

publishes the classification certificate of a cables family

LSFIRE/E01192 Rev.01

- Intended use of the product

CABLES FOR PHOTOVOLTAIC SYSTEMS AND POWER with the objective of limiting the generating and spread of fire and smoke

- Name of the manufacturer

SPECIALCAVI BALDASSARI SRL

Via G.Pieraccini 76 - 55012 Capannori(LU) - Italy

Tel. +39 0583 935741 Fax 0583 429474 Email: cpr@specialcavibaldassari.it

www.specialcavibaldassari.it/dop

The performance of the product identified above is in conformity with the set of declared performances.
This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

Capannori, 11/02/2020

Signed for and on behalf of the manufacturer by

Marco Baldassari
Chief Executive Officer

